

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-191622-01**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**Product(s):** Building hardware - Controlled door closing devices - Requirements and test methods (refer to attached appendix for details and conditions)

**Placed on the market under the name or trade mark of:** Zhaoqing New Ganan hardware Precision Manufacturing Co., Ltd., Jinsheng Industrial Park, Jinli Town, Gaoyao District, Zhaoqing City, Guangdong, China.

**and produced in the manufacturing plant(s):** Zhaoqing New Ganan hardware Precision manufacturing Co., Ltd., Jinsheng Industrial Park, Jinli Town, Gaoyao District, Zhaoqing City, Guangdong, China.

**Intended use:** On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 1154:1996/A1:2002/AC:2006**

Under System 1 for the performances set out in this certificate are applied and that the performance of the construction product fulfils all the prescribed requirements for these performances.

This certificate was first issued on **2019-09-13** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.



**0905**

*The issued document and statement(s) herein makes reference only to a presumption of conformity in accordance with the CPR Regulations EU 305/2011 (as amended). However, it is the manufacturer's or their authorised representative's sole responsibility to affix the CE logo and, by doing so, confirms full compliance and conformity to all other European mandatory directives and regulations that may also apply.*

**Signature:**

  


**Date:** 2019-09-13

**Issue:** 01

**Name:**

Dipl.-Ing. Roland Heine

**Position:** Certification Manager

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-191622-01

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-191622-01

Brand: ENIKING  
Model Ref: EK-84, EK-86

**Table A1. Mechanical test report & Product classification for Door Closer from Zhaoqing New Ganan Hardware Precision Manufacturing Co., Ltd.**

Test Report	Model tested	Product Classification					
181025132GZU-001	EK-84	3	8	3	1 <sup>a</sup>	1	2
<b>Evaluated function:</b> Floor spring, Fixed Power Size 3, with speed control and latch control							
Model EK-86 was assessed as having the same performance							

**Table A2. Fire test report for Door Closer from Zhaoqing New Ganan Hardware Precision Manufacturing Co., Ltd.**<sup>b</sup>

Test Report	Model tested	Test Method	Fire resistance (minutes)	
			E - Integrity	I - Insulation
190522012SHF-001-R1	EK-84	EN 1634-1:2014+A1:2018	68	68
Model EK-86 was assessed as having the same performance				

Notes.

- Digit 4 grade "1" was based on the test result from fire resistance test (refer to Table A2).
- The door closer shall be installed in accordance with the installation instructions for the product(s).



# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-191622-01

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-191622-01

Table A3. EN 1154 Annex ZA Related Information for Door Closer from Zhaoqing New Ganan hardware Precision Manufacturing Co., Ltd.

Product:	Controlled door closing devices EK-84, EK-86	
Intended use:	On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors) – <Floor Spring>	
Requirement/characteristic	Standard clause	Result Summary
Self-closing	General (5.2.1)	Grade 3 (closing doors from at least 120° open)
	Closing moment (5.2.3)	Power size 3
	Opening moment (5.2.4)	Power size 3
	Efficiency (5.2.5)	Power size 3: More than 55%
	Closing time (5.2.6)	Pass
	Angles of operation (5.2.7)	Grade 3, 120°
	Overload performance (5.2.8)	Pass
	Temperature dependence (5.2.9)	Pass ( -15°C to +40°C)
	Fluid leakage (5.2.10)	Pass
	Damage (5.2.11)	Pass
	Latch control (5.2.12)	Pass
	Backcheck (5.2.13)	NPD (No Performance Determined)
	Delayed closing (5.2.14)	NPD
	Adjustable closing force (5.2.15)	NPD
Zero position (5.2.16)	NPD	
Durability of self-closing	Fire/smoke door suitability (5.2.18), Annex A	Grade 1, Suitable for use on fire/smoke doors (refer to Table A2).
	Durability (5.2.2)	500,000 test cycles
Durability of self-closing	Corrosion resistance (5.2.2 5.2.17.1, 5.2.17.2)	Grade 2, Neutral Salt Spray (NSS) for 48 hours
	Dangerous substances	See Clause ZA.3
		No dangerous substances declared for this product/intended use

END OF DOCUMENT

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.